

# CODE CALL

## NEW BRUNSWICK ASSISTED LIVING FACILITY

### CONTACT

NOTES

CALL WITH	JOHN GRISHAM		FIRE MARSHAL, NEW BRUNSWICK		
DEPARTMENT	N/A	BUILDING	<b>FIRE</b>	WATER	OTHER

### BUILDING CODE

NOTES

IBC	N/A	2000	2003	2006	<b>2009</b>	2012	2015	2018
NFPA 101	N/A	2003	2006	2009	<b>2012</b>	2015	2018	OTHER

### STANDARDS

NOTES

EDITIONS USED	ADOPTED SPECIFICALLY		<b>ALL BY REFERENCE</b>		OTHER			
NFPA 13	N/A	2002	<b>2007</b>	2010	2013	2016	2019	OTHER
NFPA 14	N/A	2002	<b>2007</b>	2010	2013	2016	2019	OTHER
NFPA 20	N/A	2002	<b>2007</b>	2010	2013	2016	2019	OTHER
NFPA 24	N/A	2002	<b>2007</b>	2010	2013	2016	2019	OTHER
NFPA 70	N/A	2002	2005	<b>2008</b>	2011	2014	2017	OTHER
NFPA 72	N/A	2002	<b>2007</b>	2010	2013	2016	2019	OTHER

### FIRE ALARM CONTROL

NOTES

REMOTE ANNUNCIATOR	N/A	NOT REQUIRED	<b>FRONT ENTRY</b>		OTHER
FACP	N/A	FRONT ENTRY	<b>BACK OF HOUSE</b>		OTHER

### DUCT DETECTION

NOTES

LOCATION	N/A	<b>PER IMC</b>	P. NFPA 90A	SUPPLY	RETURN	BOTH	OTHER
SIGNAL	N/A	ALARM		<b>SUPERVISORY</b>		OTHER	
UNIT SHUTDOWN	N/A	<b>SHUTDOWN ALL</b>		SHUTDOWN UNIT		OTHER	

### MONITORING

NOTES

CENTRAL STATION	N/A	<b>NOT REQUIRED</b>	REQUIRED	OTHER
-----------------	-----	---------------------	----------	-------

### SECURITY

NOTES

KNOX BOX	N/A	NOT REQUIRED	<b>REQUIRED</b>		OTHER
KNOX BOX MONITORING	N/A	<b>NOT REQUIRED</b>	F.A. TAMPER SWITCH		OTHER
IN POWER LOSS	N/A	BLDG MUST UNLOCK	<b>FAIL SECURE PERMITTED</b>		OTHER

### FDC

NOTES

DISTANCE TO HYDRANT	N/A	50 FT	<b>100 FT</b>	150 FT	200 FT	300 FT	400 FT	OTHER
LOCATION	N/A	<b>RISER WALL</b>		REMOTE	OTHER			
TYPE	N/A	SIAMESE	<b>4" STORZ</b>	5" STORZ	OTHER			
CAP	N/A	NOT REQUIRED	<b>KNOX LOCKING CAP</b>		OTHER			

### BACKFLOW

NOTES

LOCATION	N/A	<b>INTERIOR</b>		EXTERIOR			
ORIENTATION	<b>HORIZONTAL</b>		<b>VERTICAL</b>		N-TYPE		Z-TYPE
TYPE	<b>DOUBLE CHECK</b>		DOUBLE CH. DETECT.		RPZ		RPZ DETECTOR

### HYDRAULICS

NOTES

REQ'D SAFETY FACTOR	N/A	<b>5 PSI</b>	10 PSI	20 PSI	5%	10%	20%	OTHER
FLOW TEST BY	<b>N/A</b>		FIRE DEPARTMENT		WATER UTILITY		CONTRACTOR/ENGINEER	

### INSPECTOR'S TEST

NOTES

INSPECTOR'S TEST	N/A	<b>RISER</b>		REMOTE	OTHER
------------------	-----	--------------	--	--------	-------

### MONITORING

NOTES

FLOW NOTIFICATION	N/A	ELECTRIC BELL	<b>HORN/STROBE</b>		WATER MOTOR GONG		
-------------------	-----	---------------	--------------------	--	------------------	--	--

### PUMP

NOTES

POWER RELIABILITY	<b>N/A</b>	RELIABLE	NOT RELIABLE
-------------------	------------	----------	--------------

### RISER ROOM

NOTES

EXTERIOR ACCESS	N/A	REQUIRED	<b>NOT REQUIRED</b>	
-----------------	-----	----------	---------------------	--

### SITE

NOTES

POST-INDICATOR VALVE	N/A	NOT REQUIRED	<b>REQUIRED</b>		
FIRE FLOW METHOD	N/A	<b>IFC APPENDIX B</b>		OTHER	

### STANDPIPE

NOTES

TYPE	N/A	<b>MANUAL</b>		SEMI-AUTOMATIC	AUTOMATIC
TYPE	N/A	<b>WET</b>		DRY	OTHER
CLASS	N/A	<b>CLASS I (2-1/2")</b>		CLASS II (1-1/2")	CLASS III (BOTH)
STAIR LANDINGS	N/A	FLOOR-LEVEL	<b>INTERMEDIATE</b>		